



REPLY TO
ATTENTION OF

DEPARTMENT OF THE ARMY
ASSISTANT CHIEF OF STAFF FOR INSTALLATION MANAGEMENT
600 ARMY PENTAGON
WASHINGTON, DC 20310-0600

DAIM-ZA

APR 05 2006

MEMORANDUM FOR RECORD

SUBJECT: The Army Standards for Urinals

1. The Army Standard for non-water using urinals is hereby approved. This standard is effective immediately for FY10 and beyond MILCON projects or major repairs not yet solicited. Retrofits will replace urinals using more than 1 gallon per flush if criteria in March 2005 technical evaluation are met.
2. The Army Installation Design Standard (IDS) entry in Chapter 3.15.2 will be added to read "Urinals. Non-water using urinals are an Army Standard for new construction and major repairs. It is a best practice to replace existing urinals using more than 1 gallon per flush if retrofit criteria are met in accordance with Waterless Urinals, Technical Evaluation, March 2005."
3. The Army Facilities Standardization Committee must approve any planned deviation from this standard prior to finalizing designs for construction or major renovation projects.

DAVID W. BARNO
LTG, GS
Assistant Chief of Staff
for Installation Management